

Conceptual Design of an Oxygen Diffuser System to Reduce Anoxic Products in Reservoir Releases

Mark Mobley, Mobley Engineering, Inc., Norris TN

R. Jim Ruane, Reservoir Environmental Management, Inc., Chattanooga, TN

For Presentation at:

Impacts of Hydrogen Sulfide at Reservoirs, Dams, and Tailwaters Workshop

July 30 and 31


Nashville, TN

Introduction:

- The US Army Corp of Engineers, Nashville District's J.Percy Priest hydropower project exhibits water quality problems each summer.
- A conceptual oxygen diffuser design to improve water quality conditions was completed in 2000.
- Objectives for the design included:
 - ★ Meet the 5 mg/L State DO standard in the turbine discharge
 - ★ Reduce the release of dissolved iron and manganese
 - ★ Eliminate the hydrogen sulfide odor

Line Diffuser:

- The Line Diffuser places oxygen in the reservoir to achieve optimized DO enhancement of hydropower releases:
 - ◆ Diffusers are located on the reservoir bottom usually along the old riverbed.
 - ◆ Oxygen bubbles are spread over a large area to obtain high oxygen transfer efficiencies.
 - ◆ Operation of the diffusers can be timed with hydro turbine operation or spread over a sufficient volume to meet peaking demands.
 - ◆ Anoxic products can be reduced in the reservoir releases.



Porous Hose

Buoyancy Pipe

Saddle Connection


Oxygen Supply Pipe

Pipe Tee Connection

Anchor

Stainless Steel Cable

Reservoir Bottom













10/31/01 8:20am









Mobley Engineering 03 6092-DC

11/14/01 11:27am











11/9/01 3:15pm





Buzzard Roost
Bubble Pattern

5 29 '97



Oxygen Supply




- Line diffusers are typically supplied with oxygen for hydro power applications
- Liquid oxygen is trucked to onsite storage tank
- Vaporization from liquid to gas provides pressure to move gas through the diffusers

Application to J. Percy Priest


- Oxygen input of the diffusers was sized to provide:
 - ★ 3 mg/L increase in turbine flow
 - ★ Satisfaction of the oxygen demands exerted during turbine operations
 - ★ Maintenance of the oxygenated forebay volume during non-turbine operation periods

Blue Ridge Forebay Oxygen Diffuser System September 14, 1994 *Centerline Dissolved Oxygen Profiles*

LEGEND:
 ····· No Oxygen Flow
 ——— 200 SCFM Oxygen



Forebay Retention Times During Turbine Operation



Forebay Retention Times During Non-Turbine Operation

Retention Time (days)
August - September Average Daily Flow (315 cfs)

Elevation	8000	7000	6000	5000	4000	3000	2000	1000
490	181.6	158.7	134.0	115.9	97.8	68.4	37.7	19.3
480								
470	33.7	28.9	24.0	20.2	17.0	11.1	6.7	3.8
460								
450								
440	38.1	32.0	27.4	21.6	16.9	9.3	6.5	3.7
430								
420	53.7	39.5	36.9	30.3	18.4	12.2	8.5	3.8
410								
400								
390								
380	8000	7000	6000	5000	4000	3000	2000	1000


Distance Upstream of the Dam

Diffuser Design Flows

J. Percy Priest Flow Rates




		TURBINE ON			
	Length	Turbine		Turbine Make-up	
	(feet)	O2 Flow (scfm)	Flux (scfm/ft)	O2 Flow (scfm)	Flux (scfm/ft)
#1	2,500	260	0.12		
#2	2,500	260	0.12		
#3	2,850			300	0.12
#4	3,150	260	0.12	63	0.12
Total	11,000	780		363	




TURBINE OFF					
Turbine Maintenance		Forebay Maintenance		Forebay Make-up	
O2 Flow (scfm)	Flux (scfm/ft)	O2 Flow (scfm)	Flux (scfm/ft)	O2 Flow (scfm)	Flux (scfm/ft)
17	negl				
		27	negl	4.7	negl
		16.5		1.4	
17		27		4.7	




												WSE (meters)
												150
												149
												148
							O2 Input (Tons/day)	0.80	0.80			147
												146
								% Input	0.1	0.1		145
									0.1	0.1		144
									0.3	0.3		143
									0.5	0.5		142
									1	1		141
									2	2		140
									2	2		139
									4	4		138
									6	6		137
									8	8		136
									10	10		135
									12	12		134
									15	15		133
O2 Input (Tons/day)	0.30	0.30	0.30	0.30	0.24	0.18			18	18		132
									21	21		131
	% Input	0.1	0.1	0.1	0.1	0.1	0.1		Diffuser # 1			130
		0.2	0.2	0.2	0.2	0.2	0.2					129
		0.4	0.4	0.4	0.4	0.4	0.4					128
		1	1	1	1	1	1					127
		3	3	3	3	3	3					126
		5	5	5	5	5	5					125
		8	8	8	8	8	8					124
		10	10	10	10	10	10					123
		13	13	13	13	13	13					122
		16	16	16	16	16	16					121
		19	19	19	19	19	19					120
		23	23	23	23	23	23					119
												118
												117
304.8	304.8	152.4	152.4	152.4	152.4	121.92	91.44	91.44	152.4	152.4		Cell Length (meters)
1000	1000	500	500	500	500	400	300	300	500	500		Cell Length (feet)

Dam





J Percy Priest Oxygen Usage 1996





Costs \$\$\$

- Estimated Costs for Oxygenation System at J Percy Priest:
 - ◆ Oxygen Supply Facility and Diffusers
 - 70 tons per day
 - 11,000 feet of diffuser
 - \$1.0M to \$1.2M capital costs
 - ◆ Operating Costs
 - 1,675 to 2,500 tons per year
 - \$172,000 to \$250,000